



OFFICE OF THE
DEPUTY SUPERINTENDENT, MAIBANG CHC
DIMA HASAO, MAIBANG-788831

NO.MRH/2021/22 - 835

DATED:14/12/2022

TO WHOM IT MAY CONCERN

This is certify that St.Xavier's School,Gidingpur,Maibang-788831,3 km
Gidingpur road,Dima Hasao was verified and found that the school has requisite
facilities for potable water,sanitation,ventilation and general cleanliness for the
entire school as per norms laid by the Govt.

Deputy Superintendent

Maibang CHC
Deputy Superintendent
Maibang Rural Hospital, D.H.C.

GOVT. OF ASSAM
OFFICE OF THE EXECUTIVE ENGINEER (PHE) HAFLONG DIVISION, HAFLONG
Email:eehaflongphe@gmail.com

No. PHEE/HFG/TB-458/2022-23/ 2036 /Dtd. Haflong the, 14/12/ 2022

To,

The Headmistress
St. Xavier's School Maibang
Dima Hasao, Assam.

Sub : Submission and renewal of Water Sample Test Report.


Madam,

With reference to the above, please find herewith the Water Sample Test Report done at District Level Laboratory (DLL), Haflong as per enclosed sheet.

This is for favour of your kind information.

Encl:- As stated above.

Yours faithfully,


Executive Engineer (PHE)
Haflong Division, Haflong.

Memo No. PHEE/HFG/TB- 458 /2022-23/
Copy to :-

/Dtd. Haflong the, _____ 2022

- 1) The Nodal officer, DLL Haflong, Haflong Division for information.
- 2) Smti. Shamsee Mehzabin, Asstt. Chemist DLL Haflong for information.


Executive Engineer (PHE)
Haflong Division, Haflong.

DISTRICT LEVEL LABORATORY, HAFLONG
PUBLIC HEALTH ENGINEERING DEPARTMENT, HAFLONG, DIMA HASAO

E-mail ID: dilhafiong@gmail.com

TEST REPORT

Test Report No.: PHED/HFG/DLL/WT-1/2021-22/.....191.....

Issue Date: 14/12/2023

| Sl. No. | SAMPLE COLLECTED BY (DATE & TIME) | PIN POINT LOCATION | TYPE OF SOURCE | DATE & TIME OF TESTING | PHYSICAL TEST | | | CHEMICAL TEST | | | | | BACTERIOLOGICAL TEST |
|-----------------------------|---|------------------------------|----------------|----------------------------------|---------------|---------------|-----------|---------------|----------|---------------|------|---------|----------------------|
| | | | | | COLOUR | ODOUR | TURBIDITY | pH VALUE | CHLORIDE | HARDNESS | IRON | NITRATE | |
| 1. | NAME:- School Staff DATE:- 14/12/23 TIME:- 9:00AM | ST. XAVIER'S SCHOOL, HAIRANG | Ringwell | DATE:- 14/12/23 TIME:- 2:00PM | Acceptable | Acceptable | 0.07 | 8.0 | 20 | 90 | 0.00 | 0.00 | — |
| DESIRABLE LIMIT :- | | | | | 1 | 6.5-8.5 | 0 | 300 | 0.3 | 45 | | | |
| MAXIMUM PERMISSIBLE LIMIT:- | | | | | 5 | No relaxation | 250 | 600 | 1 | No relaxation | | | |
| UNIT :- | | | | | NTU | pH Units | Mg/L | Mg/L | Mg/L | Mg/L | | | |

TEST PERFORMED BY

CHECKED BY

APPROVED BY

COUNTERSIGNED BY

[Signature]
Quality Manager
LL Hafiong, Dima Hasao

[Signature]
Lab-in-Charge
DLL Hafiong, Dima Hasao

[Signature]
Nodal Officer
DLL Hafiong, Dima Hasao

[Signature]
Executive Engineer (PHE)
Hafiong Division, Hafiong

